



Laboratory Compaction Characteristics of Soil Using Standard Effort



Optimum Moisture Content	8.2	%	Preparation	ASTM dry preparation method
Maximum Dry Unit Weight	134.7	pcf	Type of rammer	Manual - 5.5lb (24.5N)
			Test Specification / Method	VTM-1
			Specific gravity - D854 water pycnometer	2.90 Historical
Cumulative material retained on:			Coarse Aggregate Specific Gravity -	
	3/4 in. sieve	0.0		
	3/8 in. sieve			
	#4 sieve			


Soil Description	Nat. Moist. %	Liquid Limit	Plasticity Index	%< #200	USCS	AASHTO
#10 Screenings						

Project: Boxley Laboratory Testing 2022 Client: Boxley Materials Sample / Source: Fieldale Test Reference/No.:	Project No.: 12:18511-A Depth (ft.): 0 - 2 Sample No.: D4S-11 Date Reported: 1/27/2023
---	---

	Office / Lab	Address	Office Number / Fax
	ECS Mid-Atlantic LLC - Roanoke	7670 Enon Drive Suite 101 Roanoke, VA 24019	(540)362-2000 (540)362-1202

Tested by	Checked by	Approved by	Date Received	Remarks
JGeil	JMurphy	JMurphy		

California Bearing Ratios (CBR) of Laboratory-Compacted Soils



TEST RESULTS (VTM-8)

Molded			Soaked			CBR (%)		Linearty Correction (in.)	Surcharge (lbs.)	Swell (%)		
Density (pcf)	Percent of Max. Dens.	Moisture (%)	Density (pcf)	Percent of Max. Dens.	Moisture (%)	0.1 in.	0.2 in.					
136.5	101.3	8.1	135.7	100.7	8.7	48.3	62.5	0.06	10	0.02		
Material Description					AASHTO	USCS	MAX. Dens. (pcf)	Optimum Moisture (%)	LL	PI	% Fines	% Gravel
#10 Screenings												

Project: Boxley Laboratory Testing 2022
 Client: Boxley Materials
 Sample / Source Fielddate
 Test Reference/No.: 1

Project No.: 12:18511-A
 Depth (ft.): 0 - 2
 Sample No.: D4S-11
 Date Reported: 1/27/2023



Office / Lab
 ECS Mid-Atlantic LLC -
 Roanoke

Address
 7670 Enon Drive
 Suite 101
 Roanoke, VA 24019

Office Number / Fax
 (540)362-2000
 (540)362-1202

Tested by	Checked by	Approved by	Date Received	Remarks
JGeil	JMurphy	JMurphy		